

## TECHNICAL DATASHEET

**Introduction:** **FireHalt 60:30** is a **BRE/LPCB Certified** lightweight symmetrical fire barrier designed to provide compartmentation in roof cavities and concealed spaces as detailed in *UK Building Regulations: Approved Document B (Fire Safety)*.

**Firehalt 60:30** is simple to fit and requires no specialist tools or fittings.

**Physical Properties:**

Description:	Non-toxic / User friendly / flexible / durable Easy to manipulate and cut to shape
Colour:	White
Coating:	Weavelock treatment including a proprietary fire resistant additive which is food safe and non-corrosive.
Minimum Thickness:	7 mm
Minimum Weight:	1900 g/m <sup>2</sup>
Fibre Diameter	> 6 micron, (classified non-respirable)

**Test Specification:** **BS 476: parts 20/22 60 minutes integrity**  
**30 minutes insulation**

Satisfies the requirements of *UK Building Regulations: Approved Document B (Fire Safety)* for fire rated cavity barriers.

**Certification Body:** **LPCB Certified Cavity Barrier Ref # 552a/03**

**Test and Assessment Authority:** Exova Warringtonfire

Access Hatch Assessment	Ref # 129848_3
Horizontal Assessment	Ref # 179691
Movement joint Assessment	Ref # 176621
Pipe Protection Assessment	Ref # 178495

BS 476 part 6: 1989 Class O (Fire propagation)  
BS 476 part 7: 1987 Class 1 (Surface spread of flame)  
ISO 1182 1990 (E): Non Combustibility  
IMO Resolution MSC.61(67) Part 1. Non Combustibility

<b>Packing &amp; Dimensions:</b>	Width:	130cm	Packed: Convoluted and individually wrapped in polythene.
	Roll Length:	6m Standard	
	Roll Area:	7.8m <sup>2</sup>	



Culimeta-Saveguard Ltd,  
+44 (0)161 344 2484  
sales@saveguard.com  
www.culimeta-saveguard.com



The information on this Data Sheet is provided in good faith. However, the company reserves the right to alter or update this data as and when additional information is received. Firehalt products should only be fitted in accordance with the guidelines provided by the manufacturer. Any deviations must be authorised by the manufacturer or their representatives.

<b>Issue No:</b>	1	<b>Page:</b>	1 of 1	<b>Dated:</b>	1 April 2017	<b>File Ref:</b>	Prodata firehalt 60_30 130cm	.pdf
------------------	---	--------------	--------	---------------	--------------	------------------	------------------------------	------